OUTFALL 1



Flap gate for 36” RCP outlet and inactive 24” RCP outlet.



Flap gate for 36” RCP outlet.

OUTFALL 1



Flap gate for inactive 24” RCP outlet.

OUTFALL 2



8’x6’ Gravity conduit outlet



3 – 36” Discharge pipes from Derby Pump Station.

OUTFALL 2



Sluice Gate Structure No. 2 (1)

OUTFALL 2



Sluice Gate Structure No. 2 (2)

OUTFALL 3



6’x6’ Gravity conduit outlet and flap gate



(1) 6’x6’ Gravity conduit outlet and flap gate (2)

OUTFALL 3



6’x6’ Gravity conduit inlet location on the ±28-Acre vacant parcel (1).



6’x6’ Gravity conduit inlet location on the ±28-Acre vacant parcel (2).

OUTFALL 4



Flap gate for 48” pressure conduit outlet and Sluice Gate Structure No. 11.

OUTFALL 4



Flap gate for 48” pressure conduit outlet (1).



Flap gate for 48” pressure conduit outlet (2).

OUTFALL 4



48” Pressure conduit – Inlet location at Special Drainage Structure No. 8.



Discharge location of 36” RCP – Drains to Special Drainage Structure No. 8.

OUTFALL 5



Sluice Gate Structure No. 10 – Outfall from Division Street Pump Station (Ansonia).



3 – 30” Discharge pipes, with flap gates, from Division Street Pump Station (Ansonia).

OUTFALL 5



6’x5’ Gravity conduit outlet and flap gate (1).



6’x5’ Gravity conduit and flap gate (2).



OUTFALL 6: At the toe of CT Route 8 embankment.



OUTFALL 7: At the toe of CT Route 8 embankment.



OUTFALL 8: Discharge pipe from CT Route 8 drainage (Southbound).



OUTFALL 9: Discharge pipe from CT Route 8 drainage (Northbound).



Sluice Gate Structure No. 8 – Discharge from Ansonia Sewage Treatment Plant.



Discharge pipes and Flap Gates from Ansonia Sewage Treatment Plant (Sluice Gate Structure No. 8).