


Service Request 1044

Record Info

Request ID:	1044	Request Type:	Effluent Non-Compliance 5 Day Report Form
Priority:	2	Entered By:	Kevin_Shlatz
Date Submitted:	6/6/2022 8:53:00 AM	Cross Street:	Factory St

Address: 1 Caroline St
Derby



District:

Comments: The City of Derby has lost our biological life in our aeration tanks. Not sure at this point what happened to them Currently our biological process is not working at all. Chlorination of final effluent is still active and working.

Private Notes:

Reporting Utility: DERBY

Date event began or was discovered: 6/6/2022

Approximate Time Event Started: 05:00 AM

Non compliance of max or min daily limit for: -OTHER - Please Describe in Notes

Non compliance of two times any limit for: -OTHER - Please Describe in Notes

Non Compliance of Monthly Limit for:

Non compliance of Seasonal limit for:

NOTES Other non compliance: MLSS and Turbidity

Details of non compliance: Currently no biological treatment at the plant. Microbiology is non-existent at this time

How was non compliance discovered: Operator inspection

Date event stopped: 6/8/2022

Approximate Time Event Ended: 07:00 AM

Cause of non compliance: A single cause was not determined.

What action taken to eliminate noncompliance: As of 6/7/22 around 4pm the new motor was installed for east secondary clarifier and put back in service. The clarifier ran with out issues for 2 hours before we left for the day. The aeration tanks looked much better this morning (6/8) with brown foaming.

Steps taken to prevent recurrence of noncompliance :

Repairs made. Collection system inspection to determine cause.

Submitter Info

Name:	shlatz, kevin	Email:	kshlatz@derbyct.gov
Address:	1 Caroline Street Derby, CT 06418		
Phone #:	203-736-1475	Extension:	
Alt. Phone #:	Extension:		
Notify:	<input checked="" type="checkbox"/>		
Please verify this info is correct:	Verify		

Activity List

Date:	6/6/2022 8:53:00 AM
User:	Kevin_Shlatz
Comments:	Service Request Open - ID 1044 Routed To: Derby, DPH Recreation, Effluent Comments: The City of Derby has lost our biological life in our aeration tanks. Not sure at this point what happened to them Currently our biological process is not working at all. Chlorination of final effluent is still active and working. Trying to get seed sludge from surrounding plants
Date:	6/9/2022 10:16:00 AM
User:	Kevin_Shlatz
Comments:	Biological life came back after fixing clarifier drive .
Date:	6/9/2022 10:16:00 AM
User:	Kevin_Shlatz
Comments:	An automated email has been sent to the submitter(s): kshlatz@derbyct.gov
Date:	6/9/2022 10:28:00 AM
User:	Kevin_Shlatz
Comments:	Service request printed by Kevin_Shlatz
Date:	6/20/2022 9:08:00 AM
User:	AStraut
Comments:	Service Request re-opened.
Date:	6/20/2022 9:14:00 AM
User:	AStraut
Comments:	Service request type changed from "Effluent Non-Compliance 2 Hour Report Form" to "Effluent Non-Compliance 5 Day Report Form" by AStraut
Date:	6/20/2022 9:14:00 AM
User:	AStraut
Comments:	Service Request rerouted to Derby, DPH Recreation, Effluent
Date:	6/20/2022 9:15:00 AM

User:	AStraut
Comments:	Report updated to a 5-day report and populated with information reported via email.

Date:	10/25/2023 7:53:00 AM
User:	Edward_Abel
Comments:	Service request printed by Edward_Abel