

**CCTV Inspections
Naugatuck River Levee System
Ansonia, CT
August-September 2010**

FOR:

**Milone and MacBroom
99 Realty Drive
Cheshire, CT 06410**



NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219




TV Inspection with Pipe-Run Graph

Project Name: DERBY-ANSONIA, CT Asset ID: SEG1/2 City: ANSONIA-DERBY CT Address: UTILITY LAYOUY NO.7

Date: 8/26/2010 Pipe Width: 8 Pipe Height: 8 Pipe Type: CMP Surface Condition:

Direction: Downstream Surveyed Footage: 45.9 Weather: Tape/Media #:



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name: JOSEPH ASSARD and Certificate Number: U-704-1474
 System Owner: MILONE & MACBROOM
 Drainage Area: 1
 Sheet No. 1

P/O No. SEG1/2 Pipeline Segment Reference: 2010/08/26 Date: 08:50 Time: UTILITY LAYOUT NO.7 Location (Street Name and Number): ANSONIA-DERBY CT Locality: ANSONIA-DERBY CT

Further Location Details: Upstream Manhole Number: MH1 Rim to Invert: Grade to Invert: Rim to Grade: 8

Downstream Manhole Number: MH2 Rim to Invert: Grade to Invert: Rim to Grade: 8

Width: C Shape: CMP Material: CMP Ln. Method: 10.0 Pipe Joint Length: 45.9 Total Length: 45.9 Length Surveyed: 45.9 Year Laid: Year Rehabilitated: 450-1 VTR 0:00:00-0:03:35 Tape/Media Number: 5

Purpose: Sewer Category: Pre-Cleaning: N Cleaned: 2010/08/26 Weather: Location Code: Additional Information:

Distance (Feet)	Video Ref	Group/ Descripto	Moulher/ Severity	Continuous Defect	S/W/L	Value Inches	%	Joint	Circumferential Location	Image Ref.	Remarks
-----------------	-----------	------------------	-------------------	-------------------	-------	--------------	---	-------	--------------------------	------------	---------


45.9	187	AMH									MH2
------	-----	-----	--	--	--	--	--	--	--	--	-----

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:		Asset ID:		City:		Address:	
DERBY-ANSONIA, CT		SEG3/1		ANSONIA-DERBY		UTILITY LAYOUT NO.7	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:			
8/26/2010		8	CMP				
Direction:	Surveyed Footage:		Weather	Tape/Media #			
Upstream	905.5						



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. SEG3/1		Pipeline Segment Reference 2010/08/26		Date 08:59		Location (Street Name and Number) UTILITY LAYOUT NO.7		Locality ANSONIA-DERBY	
Further Location Details									
Downstream Manhole Number MH1		Upstream Manhole Number MH3		Rim to Invert		Rim to Invert		Rim to Grade	
Width		Shape		Material		Ln. Method		Pipe Joint Length	
		C		CMP				10.0	
Grade to Invert		Rim to Grade		Length Surveyed		Year Laid		Direction	
905.5		905.5		905.5				U	
Total Length		Year Rehabilitated		Tape/Media Number		vtr		Height	
905.5				450-1 VTR		0:03:35-/450-3		8	
						0:10:32-0:18:4			
						7			

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information				
		N	2010/08/26							
Distance (Feet)	Video Ref.	Group/ Descripto-	Modifier/ Severity	Continuous Defect	S/M/L	Value Inches	Joint	Circumferential Location	Image Ref.	Remarks
336.1	1405	TFA				6		12		CLEAN OUT
201.4	568	TFA				6		12		
569.4	508	ACOM								clean out

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

SEG4/5

City:

ANSONIA-DERBY

Address:

UTILITY LAOUT NO.6/7

Date

8/27/2010

Pipe Width:

Pipe Height:

48

Pipe Type:

RCP

Surface Condition:

Direction:


Downstream

Surveyed Footage:

304.0

Weather

Tape/Media #



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD	and Certificate Number U-704-1474	System Owner MILONE & MACBROOM	Drainage Area	Sheet No. 1
P/O No. SEG4/5	Pipeline Segment Reference 2010/08/27	Date 08:36	Location (Street Name and Number) UTILITY LAOUT NO.6/7	Locality ANSONIA-DERBY
Further Location Details				
Downstream Manhole Number MH5	Upstream Manhole Number MH4	Rim to Invert	Grade to Invert	Rim to Grade
Material RCP	Ln. Method	Pipe Joint Length 5.0	Total Length 304.0	Length Surveyed 304.0
Shape C	Year Rehabilitated	Year Laid	Flow Control	Height 48
Tape/Media Number 450-1 VTR		0:45:25-0:49:15		


Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information					
		N	2010/08/26								
Distance (Feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	S/M/L	Value Inches	%	Joint	Circumferential Location	Image Ref.	Remarks
304.0	235	AMH				1st	2nd		at	to	
											MH5

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	MH5/PS1	ANSONIA-DERBY	UTILITY LAYOUT NO.7	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
8/27/2010		54	RCP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Downstream	517.0			



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. MH5/PS1		Pipeline Segment Reference MH5/PS1		Date 2010/08/27		Time 08:49		Location (Street Name and Number) UTILITY LAYOUT NO.7	
Further Location Details		Upstream Manhole Number MH5		Rim to Invert		Grade to Invert		Rim to Grade	
Downstream Manhole Number PS1		Rim to Invert		Grade to Invert		Use of Sewer		Direction D	
Width C		Material RCP		Ln. Method 5.0		Pipe Joint Length 5.0		Length Surveyed 517.0	
Shape C		Rim to Invert		Grade to Invert		Total Length 517.0		Year Laid	
Height 54		Flow Control		Year Rehabilitated		Tape/Media Number 450-1 VTR		0:49:15-0:58:08	

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information
		J	2010/08/26			

Distance (Feet)	Video Ref.	Group/ Descripto	Modifier/ Severity	Continuous Defect	SYM/L	Value Inches	%	Joint	Circumferential Location	Image Ref.	Remarks
517.0	548	AMH							at to		PS1

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

MH7/4

City:

ANSONIA-DERBY

Address:

UTILITY LAYOUT NO.6

Date

8/27/2010

Pipe Width:

Pipe Height:

48

Pipe Type:

RCP

Surface Condition:

Direction:


Upstream

Surveyed Footage:

409.8

Weather

Tape/Media #



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference MH7/4		Date 2010/08/27		Time 09:38		Location (Street Name and Number) UTILITY LAYOUT NO.6	
Further Location Details		Upstream Manhole Number MH7		Rim to Invert		Grade to Invert		Locality ANSONIA-DERBY	
Downstream Manhole Number MH4		Rim to Invert		Grade to Invert		Use of Sewer		Direction U	
Width C		Material RCP		Ln. Method		Pipe Joint Length 5.0		Length Surveyed 409.8	
Total Length 409.8		Year Laid		Year Rehabilitated		Tape/Media Number 450-1 VTR		Height 48	

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information
		N	2010/08/26			


Distance (Feet)	Video Ref.	Group/Descriptor	Severity	Continuous Defect	S/M/L	Value Inches	Joint	Circumferential Location	Image Ref.	Remarks
						1st	2nd	at	to	
40.1	146	CL		S1				12		
56.4	146	CL		F1				12		
409.8	533	AMH								MH7

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:		Asset ID:		City:		Address:	
DERBY-ANSONIA, CT		MH8/7		ANSONIA-DERBY		UTILITY LAYOUT NO.6	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:			
8/27/2010		42	RCP				
Direction:	Surveyed Footage:		Weather	Tape/Media #			
Upstream	258.6						



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference MH8/7		Date 2010/08/27		Time 09:52		Location (Street Name and Number) UTILITY LAYOUT NO.6	
Further Location Details		Upstream Manhole Number MH8		Rim to Invert		Grade to Invert		Rim to Grade	
Downstream Manhole Number MH7		Rim to Invert		Grade to Invert		Length Surveyed 258.6		Year Rehabilitated	
Width		Shape C		Material RCP		Ln. Method		Pipe Joint Length 5.0	
Total Length 368.0		Rim to Grade		Use of Sewer		Direction U		Flow Control	
Height 42		Tape/Media Number 450-1 VTR		Year Laid		Year Rehabilitated		1:06:51-/450-2	
0:26:05									

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information
		N	2010/08/26			


Distance (Feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	S/M/L	Value Inches	Joint	Circumferential Location	Image Ref.	Remarks
						1st	2nd	%	at	to
121.3	121	TFA				24			9	

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:		Asset ID:		City:		Address:	
DERBY-ANSONIA, CT		MH9/8		ANSONIA-DERBY		UTILITY LAYOUT NO.6	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:			
8/27/2010		36	RCP				
Direction:	Surveyed Footage:		Weather	Tape/Media #			
Downstream	89.1						






Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner		Survey Customer MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference MH9/8		Date 2010/08/27		Time 11:40		Location (Street Name and Number) UTILITY LAYOUT NO.6		Locality ANSONIA-DERBY	
Further Location Details				Upstream Manhole Number MH9		Rim to Invert		Grade to Invert		Rim to Grade	
Downstream Manhole Number MH8		Rim to Invert		Grade to Invert		Rim to Grade		Use of Sewer		Direction D	
Width		Shape C		Material RCP		Ln. Method		Pipe Joint Length 5.0		Height 36	
Purpose		Sewer Category		Pre-Cleaning N		Cleaned 2010/08/26		Weather		Location Code	
Video Ref.		Group/Descriptor		Severity		Continuous Defect		S/N/L		Value Inches	
Distance (Feet)		89.1		146		AMH		Joint		Circumferential Location	
								at		to	
								1st		2nd	
								%		Remarks	
								Additional Information		Year Rehabilitated	
								Length Surveyed 89.1		Year Laid	
								Total Length 89.1		Tape/Media Number 450-1 VTR	
								Rim to Invert		1:07:52	
								Grade to Invert		-1:10:06	

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	MH10/9	ANSONIA-DERBY	UTILITY LAYOUT NO5/6	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
8/27/2010		30	RCP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Upstream	200.0			



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report


Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. MH10/9		Pipeline Segment Reference MH10/9		Date 2010/08/27		Time 12:10		Location (Street Name and Number) UTILITY LAYOUT NO5/6	
Further Location Details		Upstream Manhole Number MH10		Rim to Invert		Grade to Invert		Locality ANSONIA-DERBY	
Downstream Manhole Number MH9		Rim to Invert		Grade to Invert		Use of Sewer		Direction U	
Material RCP		Ln. Method		Pipe Joint Length 5.0		Length Surveyed 200.0		Year Laid Year Rehabilitated	
Shape C		Pre-Cleaning N		Cleaned 2010/08/26		Total Length 200.0		Tape/Media Number 450-1 VTR	
Width		Purpose Sewer Category		Weather		Location Code		1:13:24-	
Distance (Feet) 200.0		Video Ref. 260		Group/Modifier/Severity AMH		Joint at		Circumferential Location to	
Remarks		Defect Continuous		S/N/L 1st		Value 2nd		Image Ref. MH10	

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:		Asset ID:		City:		Address:	
DERBY-ANSONIA, CT		PS1/STR7		ANSONIA-DERBY		UTILITY LAYOUT NO.7	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:			
8/27/2010		54	RCP				
Direction:	Surveyed Footage:		Weather	Tape/Media #			
Upstream	305.3						



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD	and Certificate Number U-704-1474	System Owner MILONE & MACBROOM	Drainage Area	Sheet No. 1
P/O No.	Pipeline Segment Reference PS1/STR7	Date 2010/08/27	Time 13:42	Location (Street Name and Number) UTILITY LAYOUT NO.7
Further Location Details		Upstream Manhole Number PS1	Rim to Invert	Grade to Invert
Downstream Manhole Number STR7	Shape C	Material RCP	Rim to Invert	Grade to Invert
Width	Ln. Method	Pipe Joint Length	Rim to Invert	Grade to Invert
		5.0		
		Total Length	Length Surveyed	Year Rehabilitated
		291.6	305.3	
		Use of Sewer	Year Laid	Year Rehabilitated
		Direction	Flow Control	Height
		U		54
				Tape/Media Number
				450-1 VTR
				1:18:00-/450-2
				0:00:00-0:10:14


Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information				
		N	2010/08/26							
Distance (Feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	S/N/L	Value Inches 1st 2nd	Joint %	Circumferential Location at to	Image Ref.	Remarks
100.9	103	TBA				18		3		
110.5	156	TBA				10		2		
291.6	443	AMH								STR7

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	SEG6/3	ASONIA-DERBY	UTILITY LAYOUT NO.7	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
8/30/2010		8	CMP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Upstream	417.5			



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. SEG6/3		Pipeline Segment Reference SEG6/3		Date 2010/08/30		Time 08:31		Location (Street Name and Number) UTILITY LAYOUT NO.7	
Further Location Details		Upstream Manhole Number CO7		Rim to Invert		Grade to Invert		Rim to Grade	
Downstream Manhole Number MH3		Rim to Invert		Grade to Invert		Use of Sewer		Direction U	
Width C		Material CMP		Ln. Method 10.0		Pipe Joint Length		Length Surveyed 417.5	
Purpose Sewer Category		Pre-Cleaning N		Cleaned 2010/08/26		Weather		Total Length 417.5	
Video Ref.		Group/ Modifier/ Descripto		S/W/L		Continuous Defect		Year Laid	
Distance (Feet)		Video Ref.		Group/ Modifier/ Descripto		S/W/L		Year Rehabilitated	
61.7		158		TFA				450-1 VTR	
63.6		200		JSM				1:28:21-	
248.7		921		RFJ					
344.5		762		MSA					
417.5		394		ACOM					


Distance (Feet)	Video Ref.	Group/ Modifier/ Descripto	S/W/L	Continuous Defect	Value Inches	Joint	Circumferential Location	Image Ref.	Remarks
61.7	158	TFA			6		12		CLEAN OUT
63.6	200	JSM	M						
248.7	921	RFJ				J	3		
344.5	762	MSA							CRAWLER COULD NOT PULL CABLE
417.5	394	ACOM							CO7

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:
DERBY-ANSONIA, CT	PS1/OF1	ANSONIA-DERBY	UTLILTY LAYOUT NO7
Date	Pipe Width:	Pipe Height:	Pipe Type:
8/30/2010	6	6	RCP
Direction:	Surveyed Footage:	Weather	Tape/Media #
Downstream	148.4		



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. PS1/OF1		Pipeline Segment Reference PS1/OF1		Date 2010/08/30		Time 11:23		Location (Street Name and Number) UTILITY LAYOUT NO7	
Further Location Details		Upstream Manhole Number PS1		Rim to Invert		Grade to Invert		Rim to Grade	
Downstream Manhole Number OF1		Rim to Invert		Grade to Invert		Use of Sewer		Direction D	
Width 6		Shape S		Material RCP		Ln. Method		Pipe Joint Length	
Total Length 148.4		Length Surveyed 148.4		Year Laid		Year Rehabilitated		Tape/Media Number 450-2	
Purpose		Sewer Category		Pre-Cleaning N		Cleaned 2010/08/26		Additional Information	

Distance (Feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	S/W/L	Value Inches	1st	2nd	%	Joint	Circumferential Location	Image Ref.	Remarks
131.2	112	AOC											
148.4	156	ADP											

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219




TV Inspection with Pipe-Run Graph

Project Name: DERBY-ANSONIA, CT Asset ID: MH2/PS1 City: ANSONIA-DERBY Address: UTILITY LAYOUT NO7

Date: 8/30/2010 Pipe Width: Pipe Height: 8 Pipe Type: CMP Surface Condition:

Direction: Downstream Surveyed Footage: 10.6 Weather: Tape/Media #:



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference MH2/PS1		Date 2010/08/30		Time 11:45		Location (Street Name and Number) UTILITY LAYOUT NO7	
Further Location Details		Upstream Manhole Number MH2		Rim to Invert		Grade to Invert		Locality ANSONIA-DERBY	
Downstream Manhole Number PS1		Rim to Invert		Grade to Invert		Use of Sewer		Direction D	
Width		Shape C		Material CMP		Ln. Method		Height 8	
Pipe Joint Length 5.0		Total Length 10.6		Length Surveyed 10.6		Year Laid		Tape/Media Number 450-2 VTR	
Purpose		Sewer Category		Pre-Cleaning N		Cleaned 2010/08/26		Year Rehabilitated 0:13:22-0:15:5	
Location Code		Weather		Additional Information		Rim to Grade		Flow Control	

Distance (Feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	S/N/L	Value Inches	1st	2nd	Joint	Circumferential Location	Image Ref.	Remarks
8.4	77		H							12		
10.3	109		AMH									PS1

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

CO7/MH7

City:

ANSONIA-DERBY

Address:

UTILITY LAYOUT NO6

Date

8/30/2010

Pipe Width:

Pipe Height:

8

Pipe Type:

CMP

Surface Condition:

Direction:


Upstream

Surveyed Footage:

80.7

Weather

Tape/Media #



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report


Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. CO7/MH7		Pipeline Segment Reference CO7/MH7		Date 2010/08/30		Time 12:45		Location (Street Name and Number) UTILITY LAYOUT NO6	
Further Location Details		Upstream Manhole Number CO7		Rim to Invert		Grade to Invert		Rim to Grade	
Downstream Manhole Number MH7	Shape C	Material CMP	Ln. Method	Rim to Invert	Grade to Invert	Rim to Grade	Length Surveyed 80.7	Year Rehabilitated	Tape/Media Number 450-2 VTR
Width				Pipe Joint Length	Total Length 80.7				0:17:44-0:22:14
Purpose		Sewer Category	Pre-Cleaning N	Cleaned 2010/08/26	Weather		Additional Information		
Distance (Feet) 80.7		Video Ref. 278	Group/Descriptor ACOM	Continuous Defect	Value Inches 1st 2nd	%	Joint	Circumferential Location at to	Image Ref.
									Remarks CO7

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	MH11/10	ANSONIA-DERBY	UTILITY LAYOUT NO5	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
8/31/2010		30	RCP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Downstream	47.1			



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. MH11/10		Pipeline Segment Reference 2010/08/31		Date 07:55		Location (Street Name and Number) UTILITY LAYOUT NOS		Locality ANSONIA-DERBY	
Further Location Details									
Downstream Manhole Number MH10		Upstream Manhole Number MH11		Rim to Invert		Grade to Invert		Rim to Grade	
Width	Shape	Material	Ln. Method	Pipe Joint Length	Grade to Invert	Rim to Grade	Length Surveyed	Year Laid	Year Rehabilitated
	C	RCP		5.0	47.1	47.1	47.1		
Tape/Media Number 450-2 VTR		Direction D		Flow Control		Height 30		Tape/Media Number 0:26:05-0:27:45	


Purpose		Sewer Category		Pre-Cleaning		Cleaned		Weather		Location Code		Additional Information	
		J		2010/08/26									
Distance (Feet)		Video Ref.		Group/Descriptor		Modifier/Severity		Continuous Defect		S/M/L		Value	
47.1		109		AMH								Inches	
												1st	
												2nd	
												to	
												Joint	
												Circumferential Location	
												Image Ref.	
												Remarks	
												MH10	

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	MH13/12	ANSONIA-DERBY	UTILITY LAYOUT NO5	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
8/31/2010		30	RCP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Upstream	58.9			



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. MH13/12		Pipeline Segment Reference 2010/08/31		Date 09:09		Location (Street Name and Number) UTILITY LAYOUT NOS		Locality ANSONIA-DERBY	
Further Location Details									
Downstream Manhole Number MH12		Upstream Manhole Number MH13		Rim to Invert		Grade to Invert		Rim to Grade	
Width	Shape	Material	Ln. Method	Pipe Joint Length	Grade to Invert	Rim to Grade	Length Surveyed	Year Laid	Year Rehabilitated
	C	RCP		5.0			58.9		450-2 VTR
Purpose				Sewer Category	Pre-Cleaning	Cleaned	Location Code	Additional Information	
					J		2010/08/26		

Distance (feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	SIM/L	Value Inches	%	Joint	Circumferential Location	Image Ref.	Remarks
58.9	160	AMH									MH13

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

MH14/13

City:

ANSOSIA-DERBY

Address:

UTILITY LAYOUT N05

Date

8/31/2010

Pipe Width:

Pipe Height:

18

Pipe Type:

RCP

Surface Condition:

Direction:


Upstream

Surveyed Footage:

360.9

Weather

Tape/Media #




HEITKAMP

PACP Sewer Report

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information
		H	2010/08/26			

[illegible]

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

MH15/13

City:

ANSONIA-DERBY

Address:

UTILITY LAYOUT NO5

Date

8/31/2010

Pipe Width:

Pipe Height:

12

Pipe Type:

CMP

Surface Condition:

Direction:


Downstream

Surveyed Footage:

23.7

Weather

Tape/Media #



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name: JOSEPH ASSARD and Certificate Number: U-70401474
 System Owner: MILONE & MACBROOM
 Drainage Area: 1
 Sheet No. 1

P/O No. MH15/13
 Pipeline Segment Reference: MH15/13
 Date: 2010/08/31
 Time: 11:50
 Location (Street Name and Number): UTILITY LAYOUT NO5
 Locality: ANSONIA-DERBY

Further Location Details
 Upstream Manhole Number: MH15
 Rim to Invert: 12
 Grade to Invert: 12
 Rim to Grade: 12

Downstream Manhole Number: MH13
 Width: C
 Shape: C
 Material: CMP
 Ln. Method: 10.0
 Pipe Joint Length: 23.7
 Total Length: 23.7
 Length Surveyed: 23.7
 Year Laid: 5
 Year Rehabilitated: 5
 Tape/Media Number: 450-2 VTR
 0:43:42-0:46:2

Purpose: Sewer Category: N
 Pre-Cleaning: 2010/08/26
 Weather: 2010/08/26
 Location Code: 2010/08/26
 Additional Information: 2010/08/26


Distance (Feet)	Video Ref.	Group/ Descripto	Modifier/ Severity	Continuous Defect	S/M/L	Value Inches	%	Joint	Circumferential Location	Image Ref.	Remarks
23.7	178	AMH									+MH13

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	MH16/15	ANSONIA-DERBY	UTILITY LAYOUT NO5	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
8/31/2010		8	CMP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Upstream	369.9			



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report


Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. MH16/15		Pipeline Segment Reference 2010/08/31		Date 12:08		Location (Street Name and Number) UTILITY LAYOUT NOS		Locality ANSONIA-DERBY	
Further Location Details									
Downstream Manhole Number MH15		Upstream Manhole Number MH16		Rim to Invert		Grade to Invert		Rim to Grade	
Shape C		Material CMP		Ln. Method		Rim to Invert		Grade to Invert	
Width		Pipe Joint Length 10.0		Total Length 369.9		Length Surveyed 369.9		Year Laid	
Purpose		Sewer Category		Pre-Cleaning N		Weather		Location Code	
Distance (Feet) 369.9		Video Ref. 377		Group/Descriptor ACOM		Continuous Defect		Remarks	
Tape/Media Number 450-2 VTR		Year Rehabilitated		Circumferential Location		Joint		Image Ref.	
0:46:25-1:28:43				at		to			

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:		Asset ID:		City:		Address:	
DERBY-ANSONIA, CT		MH15/6		ANSONIA-DERBY		UTILITY LAYOUT N05/6	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:			
8/31/2010		8	CMP				
Direction:	Surveyed Footage:		Weather	Tape/Media #			
Upstream	492.7						



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name: JOSEPH ASSARD and Certificate Number: U-704-1474 System Owner: MILONE & MACBROOM Drainage Area: Sheet No. 1

P/O No. MH15/6 Pipeline Segment Reference: MH15/6 Date: 2010/08/31 Time: 13:32 Location (Street Name and Number): UTILITY LAYOUT N05/6 Locality: ANSONIA-DERBY

Further Location Details: Upstream Manhole Number: MH15 Rim to Invert: Grade to Invert: Rim to Grade: Grade to Invert: Rim to Grade: Rim to Grade

Downstream Manhole Number: MH6 Width: C Shape: CMP Material: CMP Ln. Method: CMP Pipe Joint Length: 10.0 Rim to Invert: Total Length: 460.0 Length Surveyed: 492.7 Year Laid: Year Rehabilitated: Tape/Media Number: 450-2 VTR 1:28:43-1:50:21

Purpose: Sewer Category: Pre-Cleaning: N Cleaned: 2010/08/26 Weather: Location Code: Additional Information:


Distance (feet)	Videos Ref.	Group/ Descripto	Modifier/ Severity	Continuous Defect	S/M/L	Value Inches	%	Joint	Circumferential Location	Image Ref.	Remarks
331.3	1031	MSA									COULD NOT CRAWL ANY MORE
160.8	302	MSA									OVERLAPPED TV

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	MH6/8	ANSONIA-DERBY	UTILITY LAYOUT N06	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
8/31/2010		8	CMP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Downstream	67.8			



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name: JOSEPH ASSARD and Certificate Number: U-70401474 System Owner: MILONE & MACBROOM Drainage Area: Sheet No. 1

P/O No. MH6/8 Pipeline Segment Reference: MH6/8 Date: 2010/08/31 Time: 15:02 Location (Street Name and Number): UTILITY LAYOUT N06 Locality: ANSONIA-DERBY

Further Location Details: Upstream Manhole Number: MH6 Rim to Invert: Grade to Invert: Rim to Grade: Grade to Invert: Rim to Grade: Height: 8

Downstream Manhole Number: MH8 Width: C Shape: CMP Material: Ln. Method: 10.0 Pipe Joint Length: 67.8 Total Length: 67.8 Length Surveyed: 67.8 Year Laid: Year Rehabilitated: Tape/Media Number: 450-2 VTR 1:50:21-END

Purpose: Sewer Category: Pre-Cleaning: N Cleaned: 2010/08/26 Weather: Location Code: Additional Information:

Distance (Feet): 67.8 Video Ref.: 156 Group/Descriptor: AMH Continuous Defect: 1st 2nd Value Inches: % Joint: Circumferential Location: at to Image Ref.: Remarks: MH8

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

MH6/CO7

City:

ANSONIA-DERBY

Address:

UTILITY LAYOUT N06

Date

8/31/2010

Pipe Width:

Pipe Height:

8

Pipe Type:

CMP

Surface Condition:

Direction:


Downstream

Surveyed Footage:

372.6

Weather

Tape/Media #



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. MH6/CO7		Pipeline Segment Reference MH6/CO7		Date 2010/08/31		Time 15:10		Location (Street Name and Number) UTILITY LAYOUT N06	
Further Location Details		Upstream Manhole Number MH6		Rim to Invert		Grade to Invert		Locality ANSONIA-DERBY	
Downstream Manhole Number CO7		Rim to Invert		Grade to Invert		Use of Sewer		Direction D	
Width C		Material CMP		Ln. Method		Pipe Joint Length 10.0		Length Surveyed 372.6	
Purpose		Sewer Category N		Pre-Cleaning 2010/08/26		Weather		Location Code	
Distance (Feet) 372.6		Video Ref. 591		Group/Descriptor ACOM		Continuous Defect		Value 1st 2nd %	
Tape/Media Number 450-3 VTR		Year Laid		Year Rehabilitated		Rim to Grade		Height 8	
0:00:00-0:10:32									

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

MH14/CO14

City:

ANSONIA-DERBY

Address:

UTILITY LAYOUT NO5

Date

9/1/2010

Pipe Width:

Pipe Height:

8

Pipe Type:

CMP

Surface Condition:

Direction:


Upstream

Surveyed Footage:

16.0

Weather

Tape/Media #



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report


Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-174		System Owner MITLONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference MH14/CO14		Date 2010/09/01		Time 10:31		Location (Street Name and Number) UTILITY LAYOUT NO5	
Further Location Details		Upstream Manhole Number MH14		Rim to Invert		Grade to Invert		Locality ANSONIA-DERBY	
Downstream Manhole Number CO14		Rim to Invert		Grade to Invert		Use of Sewer		Direction U	
Width		Shape C		Material CMP		Ln. Method		Flow Control	
Height		Pipe Joint Length 10.0		Total Length 16.0		Length Surveyed 16.0		Year Laid	
Purpose		Sewer Category		Pre-Cleaning N		Cleaned 2010/08/26		Tape/Media Number 450-3 VTR	
Location Code		Weather		Additional Information		Year Rehabilitated		0:18:47-0:20:06	
Distance (Feet)		Video Ref.		Group/Descriptor		Modifier/Severity		Remarks	
16.0		89		ACOM		CO14			

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	MH17/CO17C	DERBY-ANSONIA	UTILITY LAYOUT NO8	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
9/1/2010		8	CMP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Upstream	431.5			



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD	and Certificate Number U-704-1474	System Owner MILONE & MACBROOM	Drainage Area	Sheet No. 1
P/O No.	Pipeline Segment Reference MH17/CO17C	Date 2010/09/01	Time 11:04	Location (Street Name and Number) UTILITY LAYOUT NO8
Further Location Details		Upstream Manhole Number MH17	Rim to Invert	Grade to Invert
Downstream Manhole Number CO17A				
Width	Shape C	Material CMP	Ln. Method	Rim to Invert
			Pipe Joint Length 10.0	
			Total Length 431.5	
			Length Surveyed 431.5	
			Year Laid	Year Rehabilitated
			Use of Sewer	Direction U
			Flow Control	Height 8
				Tape/Media Number 450-3 VTR
				0:20:06-0:36:30

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information
		N	2010/08/26			

Distance (Feet)	Video Ref.	Group/ Descripto	Modifier/ Severity	Continuous Defect	S/M/L	Value Inches	Joint	Circumferential Location	Image Ref.	Remarks
225.4	737	ACOM								CO17
431.5	996	ACOM								CO17A

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

MH17/18

City:

DERBY -ANSONIA

Address:

UTILITY LAYOUT N08

Date

9/1/2010

Pipe Width:

Pipe Height:

8

Pipe Type:

CMP

Surface Condition:

Direction:


Downstream

Surveyed Footage:

355.0

Weather

Tape/Media #



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name: JOSEPH ASSARD and Certificate Number: U-704-1474 System Owner: MILONE & MACBROOM Drainage Area: Sheet No. 1

P/O No. MH17/18 Pipeline Segment Reference: MH17/18 Date: 2010/09/01 Time: 12:36 Location (Street Name and Number): UTILITY LAYOUT N08 Locality: DERBY - ANSONIA

Further Location Details: Upstream Manhole Number: MH17 Rim to Invert: Grade to Invert: Rim to Grade: Grade to Invert: Rim to Grade: Height: 8

Downstream Manhole Number: MH18 Width: C Shape: CMP Material: CMP Ln. Method: CMP Pipe Joint Length: 10.0 Rim to Invert: Grade to Invert: Total Length: 355.0 Length Surveyed: 355.0 Year Laid: Year Rehabilitated: Tape/Media Number: 450-3 VTR 0:36:30-0:46:31

Purpose: Sewer Category: Pre-Cleaning: J Cleaned: 2010/08/26 Weather: Location Code: Additional Information:

Distance (Feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	S/M/L	Value Inches	1st	2nd	%	Joint	Circumferential Location	Image Ref.	Remarks
-----------------	------------	------------------	-------------------	-------------------	-------	--------------	-----	-----	---	-------	--------------------------	------------	---------


205.5	272	ACOM											CO18
355.0	577	AMH											MH18

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	MH20/19	DERBY -ANSONIA	UTILITY LAYOUT N08	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
9/1/2010		48	RCP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Upstream	357.5			



PACP Sewer Report

Sheet No.

Locality
DERBY - ANSONIA

Grade to Invert48
Height

Tape/Media Number
450-3 VTR
0:46:31-0:
9

Additional Information

RemarksMH20

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

MH19/OF2

City:

DERBY-ANSONIA

Address:

UTILITY LAYOUT NO8

Date

9/1/2010

Pipe Width:

4

Pipe Height:

4

Pipe Type:

RCP

Surface Condition:

Direction:


Downstream

Surveyed Footage:

160.0

Weather

Tape/Media #



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MTLONE & MACBROOM		Survey Customer MTLONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference MH19/OF2		Date 2010/09/01		Time 15:08		Location (Street Name and Number) UTILITY LAYOUT NO8		Locality DERBY-ANSONIA	
Further Location Details											
Downstream Manhole Number OF2		Upstream Manhole Number MH19		Rim to Invert		Grade to Invert		Rim to Invert		Rim to Grade	
Width 4	Shape S	Material RCP	Ln. Method	Pipe Joint Length 5.0	Rim to Invert	Grade to Invert	Rim to Grade	Length Surveyed 160.0	Use of Sewer	Direction D	Flow Control
Tape/Media Number 450-3 VTR		Year Rehabilitated		Year Laid		Height 4		Tape/Media Number 0:56:49-1:00:46			

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information							
		N	2010/08/26										
Distance (Feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	S/M/L	Valde Inches	1st	2nd	%	Joint	Circumferential Location	Image Ref.	Remarks
130.5	125		AOC										
160.0	205		ADP										OF2

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

MH21/20

City:

DERBY-ANSONIA

Address:

UTILITY LAYOUT NO8

Date

9/2/2010

Pipe Width:

Pipe Height:

48

Pipe Type:

CMP

Surface Condition:

Direction:


Downstream

Surveyed Footage:

305.2

Weather

Tape/Media #





PACP Sewer Report

Surveyors Name	System Owner	Drainage Area	Sheet No.
and Certificate Number	Survey Customer		


Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:		Asset ID:		City:		Address:	
DERBY-ANSONIA, CT		MH22/21		DERBY-ANSONIA		UTILITY LAYOUT N08	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:			
9/2/2010		48	RCP				
Direction:	Surveyed Footage:		Weather	Tape/Media #			
Upstream	462.9						



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. MH22/21		Pipeline Segment Reference MH22/21		Date 2010/09/02		Time 08:56		Location (Street Name and Number) UTILITY LAYOUT NO8	
Further Location Details		Upstream Manhole Number MH22		Rim to Invert		Grade to Invert		Locality DERBY-ANSONIA	
Downstream Manhole Number MH21		Rim to Invert		Grade to Invert		Use of Sewer		Direction U	
Width C		Material RCP		Ln. Method		Pipe Joint Length 5.0		Length Surveyed 462.9	
Shape C		Rim to Invert		Grade to Invert		Total Length 462.9		Year Laid	
Purpose		Sewer Category		Pre-Cleaning N		Cleaned 2010/08/26		Tape/Media Number 450-3 VTR	
Location Code		Weather		Additional Information		Year Rehabilitated		1:05:08-1:11:3	
Distance (Feet)		Video Ref.		Group/Descriptor/Severity		Continuous Defect		S/M/L	
462.9		393		AMH		1st		2nd	
Joint		Circumferential Location		Image Ref.		Remarks			
at		to		MH22					

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

STR8/MH22

City:

DERBY-ANSONIA

Address:

UTILITY LAYOUT NO8

Date

9/2/2010

Pipe Width:

Pipe Height:

48

Pipe Type:

RCP

Surface Condition:

Direction:

Upstream


Surveyed Footage:

178.4

Weather

Tape/Media #

Asset length: 178.4 ft.
 Surveyed length: 178.4 ft.



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyor's Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. STR8/MH22		Pipeline Segment Reference STR8/MH22		Date 2010/09/02		Time 09:07		Location (Street Name and Number) UTILITY LAYOUT NO8	
Further Location Details		Upstream Manhole Number STR8		Rim to Invert		Grade to Invert		Rim to Grade	
Downstream Manhole Number MH22		Rim to Invert		Grade to Invert		Use of Sewer		Direction U	
Width C		Material RCP		Ln. Method		Pipe Joint Length 5.0		Length Surveyed 178.4	
Total Length 178.4		Rim to Grade		Year Laid		Year Rehabilitated		Tape/Media Number 450-3 VTR	
Height 48		Flow Control		Year Rehabilitated		Tape/Media Number 1:11:33-1:17:1		5	
Purpose		Sewer Category		Pre-Cleaning		Cleaned		Weather	
Location Code		2010/08/26		Additional Information					

Distance (Feet)	Video Ref.	Group/ Descripto	Modifier/ Severity	Continuous Defect	S/M/L	Value Inches	1st	2nd	%	Joint	Circumferential Location	Image Ref.	Remarks
155.3	151	ACB											STR8
155.3	0	MSC				36							
178.4	323	ACB											

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

WELL 1/ B1

City:

DERBY-ANSONIA

Address:

DERBY SHEET 5

Date

9/2/2010

Pipe Width:

Pipe Height:

10

Pipe Type:

CMP

Surface Condition:

Direction:


Downstream

Surveyed Footage:

32.0

Weather

Tape/Media #



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference WELL 1/ B1		Date 2010/09/02		Time 10:12		Location (Street Name and Number) DERBY SHEET 5	
Further Location Details		Upstream Manhole Number WELL 1		Rim to Invert		Grade to Invert		Locality DERBY-ANSONIA	
Downstream Manhole Number B1	Shape C	Material CMP	Ln. Method	Rim to Invert	Grade to Invert	Length Surveyed 32.0	Rim to Grade	Flow Control	Height 10
Width				Pipe Joint Length	Total Length 32.0	Year Laid	Year Rehabilitated	Tape/Media Number 450-3 VTR	
								1:17:15:1:21:5	
								4	

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information
		N	2010/08/26			


Distance (feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Detec	S/M/L	Value Inches	%	Joint	Circumferential Location	Image Ref.	Remarks
						1st	2nd		at	to	
32.0	0	AWW									

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:
DERBY-ANSONIA, CT	WELL2/B2	DERBY-ANSONIA	DERBY SHEET 5
Date	Pipe Width:	Pipe Height:	Pipe Type:
9/2/2010		10	CMP
Direction:	Surveyed Footage:	Weather	Tape/Media #
Downstream	30.0		



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report


Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference WELL2/B2		Date 2010/09/02		Time 10:37		Location (Street Name and Number) DERBY SHEET 5	
Further Location Details		Upstream Manhole Number WELL 2		Rim to Invert		Grade to Invert		Locality DERBY-ANSONIA	
Downstream Manhole Number B2		Rim to Invert		Grade to Invert		Use of Sewer		Direction D	
Width C		Material CMP		Ln. Method		Pipe Joint Length		Flow Control	
Height 10		Total Length 30.0		Rim to Grade		Length Surveyed 30.0		Year Laid	
Purpose		Sewer Category		Pre-Cleaning Cleaned		Weather		Year Rehabilitated	
Distance (Feet) 30.0		Video Ref. 126		Group/Descriptor AWW		Location Code		Tape/Media Number 450-3 VTR	
Continuous Defect		S/M/L		Value 1st 2nd		Joint at		Remarks WELL2	
Pre-Cleaning		N		Additional Information		Circumferential Location		Height 10	
Cleaned		N		Location Code		Circumferential Location		Tape/Media Number 450-3 VTR	
Cleaned		N		Location Code		Circumferential Location		1:21:54-1:23:54	

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	WELL3/B3	DERBY-ANSONIA	DERBY SHEET 5	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
9/2/2010		10	CMP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Downstream	28.0			



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report


Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference WELL3/B3		Date 2010/09/02		Time 10:49		Location (Street Name and Number) DERBY SHEET 5	
Further Location Details		Upstream Manhole Number WELL3		Rim to Invert		Grade to Invert		Locality DERBY-ANSONIA	
Downstream Manhole Number B3		Rim to Invert		Grade to Invert		Use of Sewer		Flow Control	
Width		Shape C		Material CMP		Ln. Method		Pipe Joint Length	
Total Length 28.0		Length Surveyed 28.0		Year Laid		Year Rehabilitated		Tape/Media Number 450-3 VTR	
Purpose		Sewer Category		Pre-Cleaning N		Cleaned 2010/08/26		Additional Information	
Distance (Feet)		Video Ref.		Group/Descriptor		Modifier/Severity		Continuous Defect	
S/M/L		Value Inches		1st		2nd		%	
Joint		Circumferential Location		at		to		Remarks	
28.0		159		AWW		WELL3			

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:	Asset ID:	City:	Address:	
DERBY-ANSONIA, CT	WELL4/B4	DERBY-ANSONIA	DERBY SHEE 5	
Date	Pipe Width:	Pipe Height:	Pipe Type:	Surface Condition:
9/2/2010		10	CMP	
Direction:	Surveyed Footage:	Weather	Tape/Media #	
Downstream	30.0			



NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No.		Pipeline Segment Reference WELL4/B4		Date 2010/09/02		Time 11:15		Location (Street Name and Number) DERBY SHEE 5	
Further Location Details		Upstream Manhole Number WELL4		Rim to Invert		Grade to Invert		Locality DERBY-ANSONIA	
Downstream Manhole Number B4		Rim to Invert		Grade to Invert		Use of Sewer		Direction D	
Width C		Material CMP		Ln. Method		Pipe Joint Length		Flow Control	
Shape C		Pre-Cleaning N		Cleaned 2010/08/26		Weather		Height 10	
Purpose		Sewer Category		Location Code		Additional Information		Tape/Media Number 450-3 VTR	
Distance (Feet) 30.0		Video Ref. 112		Group/Modifier/Descriptor AWW		Continuous Defect		Year Rehabilitated	
S/M/L		Value Inches		Joint		Circumferential Location		Year Laid	
1st		2nd		%		at		Rim to Grade	
30.0		112		AWW		WELL4		8	

NEPCCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



TV Inspection with Pipe-Run Graph

Project Name:

DERBY-ANSONIA, CT

Asset ID:

INLT1/OF3

City:

DERBY-ANSONIA

Address:

DERBY SHEET 4

Date

9/2/2010

Pipe Width:

6

Pipe Height:

6

Pipe Type:

RCP

Surface Condition:

Direction:


Downstream

Surveyed Footage:

133.2

Weather

Tape/Media #



NEPCO Division Heitkamp, Inc.
 99 Callender Road
 Watertown, CT 06795
 Phone: (860) 274-5469
 Fax: (860) 945-3219



PACP Sewer Report

Surveyors Name JOSEPH ASSARD		and Certificate Number U-704-1474		System Owner MILONE & MACBROOM		Drainage Area		Sheet No. 1	
P/O No. INLT1/OF3		Pipeline Segment Reference INLT1/OF3		Date 2010/09/02		Time 12:02		Location (Street Name and Number) DERBY SHEET 4	
Further Location Details		Upstream Manhole Number INLT1		Rim to Invert		Grade to Invert		Rim to Grade	
Downstream Manhole Number OF3		Rim to Invert		Grade to Invert		Use of Sewer		Direction D	
Width 6		Shape S		Material RCP		Ln. Method		Total Length 133.2	
Length Surveyed 133.2		Year Laid		Year Rehabilitated		Tape/Media Number 450-3 VTR		1:28:28-1:33:27	

Purpose	Sewer Category	Pre-Cleaning	Cleaned	Location Code	Weather	Additional Information
		N				2010/08/26

Distance (Feet)	Video Ref.	Group/Descriptor	Modifier/Severity	Continuous Defect	S/M/L	Value Inches	%	Joint	Circumferential Location	Image Ref.	Remarks
						1st	2nd		at	to	
130.3	236		AOC								
133.2	276		ADP								

NEPCCO Division Heitkamp, Inc.
99 Callender Road
Watertown, CT 06795
Phone: (860) 274-5469
Fax: (860) 945-3219




TV Inspection with Pipe-Run Graph

Project Name: DERBY-ANSONIA, CT Asset ID: MH12/11 City: ANSONIA-DERBY Address: UTILITY LAYOUT N05

Date: 8/31/2010 Pipe Width: Pipe Height: 30 Pipe Type: RCP Surface Condition:

Direction: Downstream Surveyed Footage: 21.2 Weather: Tape/Media #:



Burning started at 9/23/2010 10:03:22 AM Burning at 9.23.2010 10.03.22 AM
Destination: DVD, D:\

Export started at 09/23/10 10:03:22

Local database: G:\10-03-3060 - Milone and MacBroom - Ansonia-Derby\Derby-ANSONIA.mdb
Export finished at 09/23/10 10:03:22

Burning disk 1 of 2, label "Ansonia-VB001"

Video files burned:

G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT- MH1-CO1-UTILITY LAYOUT NO7.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-CO7-MH3-UTILITY LAYOUT NO.7.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-CO7-MH7-UTILITY LAYOUT NO6.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-INLT1-OF3-DERBY SHEET 4.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH1 -MH2-UTILITY LAYOUT NO.7.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH10-MH9-UTILITY LAYOUT
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH11-MH10-UTILITY LAYOUT NO5.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH12-MH11-UTILITY LAYOUT NO5.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH12-MH11-UTILITY LAYOUT
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH13-MH12-UTILITY LAYOUT NO5.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH14-CO14-UTILITY LAYOUT NO5.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH14-MH13-UTILITY LAYOUT NO5.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH15-MH13-UTILITY LAYOUT NO5.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH15-MH6-UTILITY LAYOUT
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH15-MH6-UTILITY LAYOUT
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH16-MH15-UTILITY LAYOUT NO5.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH16-MH15-UTILITY LAYOUT
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH17-CO17A-UTILITY LAYOUT
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH17-MH18-UTILITY LAYOUT NO8.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH19-OF2-UTILITY LAYOUT NO8.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH2-PS1-UTILITY LAYOUT NO7.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH20-MH19-UTILITY LAYOUT NO8.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH21-MH20-UTILITY LAYOUT NO8.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH22 -MH21-UTILITY LAYOUT
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH3-MH1 -UTILITY LAYOUT NO.7.mpg
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH3-MH1 -UTILITY LAYOUT
G:\10-03-3060 - Milone and MacBroom	- Ansonia-Derby\Media\Video\Derby-ANSONIA,	CT-MH3-MH1 -UTILITY LAYOUT

Burning at 9.23.2010 10.03.22 AM

G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH4-MH5-UTILITY LAOUT NO.6.7.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH5-PS1-UTILITY LAYOUT NO.7.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH6- CO7-UTILITY LAYOUT NO6.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH6-MH8 -UTILITY LAYOUT NO6.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH8 -MH7-UTILITY LAYOUT
NO.6.mpg			
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-STR8-MH22 -UTILITY LAYOUT
NO80.mpg			
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-WELL 1-B1-DERBY SHEET 5.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-WELL4-B4-DERBY SHEE 5.mpg
Burning disk 2 of 2, label "Ansonia-VB002"			
Video files burned:			
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH6-MH3-UTILITY LAYOUT NO.7.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH6-MH3-UTILITY LAYOUT NO.71.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH7-MH4-UTILITY LAYOUT NO.6.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH8 -MH7-UTILITY LAYOUT
NO.60.mpg			
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH8 -MH7-UTILITY LAYOUT
NO.61.mpg			
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-MH9-MH8 -UTILITY LAYOUT
NO.6.mpg			
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-PS1-OF1-UTLILTY LAYOUT NO7.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-PS1-STR7-UTILITY LAYOUT NO.7.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-PS1-STR7-UTILITY LAYOUT
NO.70.mpg			
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-STR8-MH22 -UTILITY LAYOUT
NO8.mpg			
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-WELL 1-B1-DERBY SHEET 50.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-WELL 2-B2-DERBY SHEET 5.mpg
G:\10-03-3060	- Milone and MacBroom	- Ansonia-Derby\Media\Video\DERBY-ANSONIA,	CT-WELL3-B3 -DERBY SHEET 5.mpg

Burning finished at 9/23/2010 10:16:50 AM

